

Effective date **January 1, 2017**

Electricians: All Wiring Installations shall be per the
2017 National Electrical Code with reference to include
CMR 12.00 Massachusetts Electrical Code Amendments

Listed below are a few New and/or Amended Requirements for residential wiring installations.

TORQUE REQUIREMENTS ----- Article 110-14D

ARC FAULT PROTECTION ----- Article 210-12 A, B, C and D
Article 410-4D for replacement of receptacles
Article 440-65
Article 550-25

COUNTERTOP PENINSULA RECEPTACLE REQUIREMENT
Article 210-52-C3

NEUTRAL CONDUCTOR INSTALLED IN SWITCH LOCATIONS
Article 404-2C

RESIDENTIAL GARAGE OUTLETS

Article 210-11C-4 (NEW) At least one 120V, 20A circuit for receptacle outlets only
Article 210-52G-1 Receptacle Outlets required at each vehicle bay not more than 66"
above the floor.

(Lighting and ceiling receptacles for door openers shall not be connected to this circuit.)
Garage receptacles require GFI Protection.