



MANCHESTER-BY-THE-SEA

BOARD OF HEALTH

TOWN HALL - 10 CENTRAL STREET

Manchester-by-the-Sea, Massachusetts 01944-1399

Telephone (978) 526-7385

FAX (978) 526-2009

July 25, 2023

29 Old Neck Rd Trust
US Trust Co c/o Judith Hood
29 Old Neck Road
Manchester-by-the-Sea, MA 01944

NOTIFICATION TO OWNER

Upon receipt of the Title 5 Inspection Report for the onsite sewage disposal system at:

Property Address: **29 OLD NECK ROAD, Manchester-By-The-Sea – Carriage House**

Property Owner: 29 OLD NECK RD TRUST / US TRUST CO c/o JUDITH HOOD

Licensed Title 5 Inspector: John M. Bennett, Cape Ann Professional Engineers SI# 1291

The Title 5 Inspection Report dated: 7/19/2023, revised signature dated 7/25/2023, states the system **PASSES**.

Note: The Title 5 Inspector has passed the on-site septic system. The Health Agent was informed of the comments in Section C.1. and agrees there is no failure criteria. The Comments section states:

"Title 5 Cesspool Inspection Guidance" suggests the 1st cesspool acts as a septic tank with overflow into the 2nd cesspool which serves as a soil absorption system. There is no evidence of overflow from the 1st cesspool into the 2nd cesspool. The system has been evaluated as a single cesspool system. The system average daily flow for the last two years has been only 38 GPD. If larger flows are introduced into the system it may fail.

The Board of Health DID NOT find the septic system, as it is now used, to constitute a danger to the public health and subsequently did not order its repair/replacement at this time.

Reviewing Board of Health Agent:

Wendy Hansbury RS, Public Health Director

THIS INSPECTION reflects the **present** condition of the sanitary disposal system and is not any guarantee as to the life or future condition of said system. A passing Title 5 Inspection Report with pump receipts for three years within each calendar year may be used for sale of property. (Explanation: If there is a potential that your home will be sold within three years, you MUST have the septic tank pumped once a year, within a year of the date of the approved Title 5 Inspection Report for each of the three years. This allows the sale to occur with the use of the pumping reports and annual receipts abates the need for a "Title 5 System Inspection" for a property transfer within three years of the passing inspection, otherwise a passing Title 5 Inspection Report is only good for two years.)



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

Inspection results must be submitted on this form. Inspection forms may not be altered in any way. Please see completeness checklist at the end of the form.

Important: When
filling out forms
on the computer,
use only the tab
key to move your
cursor - do not
use the return
key.



A. Inspector Information

John M. Bennett

Name of Inspector

Cape Ann Professional Engineers

Company Name

5 Knight Road

Company Address

Manchester

City/Town

978-526-8254

Telephone Number

MA

State

01944

Zip Code

SI 1291

License Number

B. Certification

I certify that: I am a DEP approved system inspector in full compliance with Section 15.340 of Title 5 (310 CMR 15.000); I have personally inspected the sewage disposal system at the property address listed above; the information reported below is true, accurate and complete as of the time of my inspection; and the inspection was performed based on my training and experience in the proper function and maintenance of on-site sewage disposal systems. After conducting this inspection I have determined that the system:

- ☒ Passes
- ☐ Conditionally Passes
- ☐ Needs Further Evaluation by the Local Approving Authority
- ☐ Fails

John M. Bennett
Inspector's Signature

7/25/2023
Date

The system inspector shall submit a copy of this inspection report to the Approving Authority (Board of Health or DEP) within 30 days of completing this inspection. If the system has a design flow of 10,000 gpd or greater, the inspector and the system owner shall submit the report to the appropriate regional office of the DEP. The original form should be sent to the system owner and copies sent to the buyer, if applicable, and the approving authority.

Please note: This report only describes conditions at the time of inspection and under the conditions of use at that time. This inspection does not address how the system will perform in the future under the same or different conditions of use.



Owner
information is
required for every
page.

Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

C. Inspection Summary

Inspection Summary: Complete 1, 2, 3, or 5 and all of 4 and 6.

1) System Passes:

- ☒ I have not found any information which indicates that any of the failure criteria described in 310 CMR 15.303 or in 310 CMR 15.304 exist. Any failure criteria not evaluated are indicated below.

Comments:

"Title 5 Cesspool Inspection Guidance" suggests the 1st cesspool acts as a septic tank with overflow into the 2nd cesspool which serves as a soil absorption system. There is no evidence of overflow from the 1st cesspool into the 2nd cesspool. The system has been evaluated as a single cesspool system. The system average daily flow for the last two years has been only 38 GPD. If larger flows are introduced into the system it may fail.

2) System Conditionally Passes:

- ☐ One or more system components as described in the "Conditional Pass" section need to be replaced or repaired. The system, upon completion of the replacement or repair, as approved by the Board of Health, will pass.

Check the box for "yes", "no" or "not determined" (Y, N, ND) for the following statements. If "not determined," please explain.

The septic tank is metal and over 20 years old* or the septic tank (whether metal or not) is structurally unsound, exhibits substantial infiltration or exfiltration or tank failure is imminent. System will pass inspection if the existing tank is replaced with a complying septic tank as approved by the Board of Health.

* A metal septic tank will pass inspection if it is structurally sound, not leaking and if a Certificate of Compliance indicating that the tank is less than 20 years old is available.

☐ Y ☐ N ☐ ND (Explain below):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

C. Inspection Summary (cont.)

2) System Conditionally Passes (cont.):

☐ Pump Chamber pumps/alarms not operational. System will pass with Board of Health approval if pumps/alarms are repaired.

☐ Observation of sewage backup or break out or high static water level in the distribution box due to broken or obstructed pipe(s) or due to a broken, settled or uneven distribution box. System will pass inspection if (with approval of Board of Health):

☐ broken pipe(s) are replaced ☐ Y ☐ N ☐ ND (Explain below):

☐ obstruction is removed ☐ Y ☐ N ☐ ND (Explain below):

☐ distribution box is leveled or replaced ☐ Y ☐ N ☐ ND (Explain below):

☐ The system required pumping more than 4 times a year due to broken or obstructed pipe(s). The system will pass inspection if (with approval of the Board of Health):

☐ broken pipe(s) are replaced ☐ Y ☐ N ☐ ND (Explain below):

☐ obstruction is removed ☐ Y ☐ N ☐ ND (Explain below):

3) Further Evaluation is Required by the Board of Health:

☐ Conditions exist which require further evaluation by the Board of Health in order to determine if the system is failing to protect public health, safety or the environment.

a. System will pass unless Board of Health determines in accordance with 310 CMR 15.303(1)(b) that the system is not functioning in a manner which will protect public health, safety and the environment:



Owner
information is
required for every
page.

Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

C. Inspection Summary (cont.)

- ☐ Cesspool or privy is within 50 feet of a surface water
- ☐ Cesspool or privy is within 50 feet of a bordering vegetated wetland or a salt marsh

b. System will fail unless the Board of Health (and Public Water Supplier, if any) determines that the system is functioning in a manner that protects the public health, safety and environment:

- ☐ The system has a septic tank and soil absorption system (SAS) and the SAS is within 100 feet of a surface water supply or tributary to a surface water supply.
- ☐ The system has a septic tank and SAS and the SAS is within a Zone 1 of a public water supply.
- ☐ The system has a septic tank and SAS and the SAS is within 50 feet of a private water supply well.
- ☐ The system has a septic tank and SAS and the SAS is less than 100 feet but 50 feet or more from a private water supply well**.

Method used to determine distance: _____

** This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis must be attached to this form.

c. Other:

4) System Failure Criteria Applicable to All Systems:

You must indicate "Yes" or "No" to each of the following for all inspections:

Yes No

☐ ☒

Backup of sewage into facility or system component due to overloaded or clogged SAS or cesspool

☐ ☒

Discharge or ponding of effluent to the surface of the ground or surface waters due to an overloaded or clogged SAS or cesspool



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

RECEIVED
JUL 24 2023
BOARD OF HEALTH

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

Owner
information is
required for every
page.

Inspection results must be submitted on this form. Inspection forms may not be altered in any way. Please see completeness checklist at the end of the form.

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



A. Inspector Information

John M. Bennett

Name of Inspector

Cape Ann Professional Engineers

Company Name

5 Knight Road

Company Address

Manchester

City/Town

978-526-8254

Telephone Number

MA

State

01944

Zip Code

SI 1291

License Number

B. Certification

I certify that: I am a DEP approved system inspector in full compliance with Section 15.340 of Title 5 (310 CMR 15.000); I have personally inspected the sewage disposal system at the property address listed above; the information reported below is true, accurate and complete as of the time of my inspection; and the inspection was performed based on my training and experience in the proper function and maintenance of on-site sewage disposal systems. After conducting this inspection I have determined that the system:

- ☐ Passes
- ☐ Conditionally Passes
- ☒ Needs Further Evaluation by the Local Approving Authority
- ☐ Fails

John M Bennett

Inspector's Signature

7/21/2023

Date

The system inspector shall submit a copy of this inspection report to the Approving Authority (Board of Health or DEP) within 30 days of completing this inspection. If the system has a design flow of 10,000 gpd or greater, the inspector and the system owner shall submit the report to the appropriate regional office of the DEP. The original form should be sent to the system owner and copies sent to the buyer, if applicable, and the approving authority.

Please note: This report only describes conditions at the time of inspection and under the conditions of use at that time. This inspection does not address how the system will perform in the future under the same or different conditions of use.



Owner
information is
required for every
page.

Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

C. Inspection Summary

Inspection Summary: Complete 1, 2, 3, or 5 and all of 4 and 6.

1) System Passes:

- ☒ I have not found any information which indicates that any of the failure criteria described in 310 CMR 15.303 or in 310 CMR 15.304 exist. Any failure criteria not evaluated are indicated below.

Comments:

"Title 5 Cesspool Inspection Guidance" suggests the 1st cesspool acts as a septic tank. There is no evidence that the 2nd cesspool is utilized.

2) System Conditionally Passes:

- ☐ One or more system components as described in the "Conditional Pass" section need to be replaced or repaired. The system, upon completion of the replacement or repair, as approved by the Board of Health, will pass.

Check the box for "yes", "no" or "not determined" (Y, N, ND) for the following statements. If "not determined," please explain.

The septic tank is metal and over 20 years old* or the septic tank (whether metal or not) is structurally unsound, exhibits substantial infiltration or exfiltration or tank failure is imminent. System will pass inspection if the existing tank is replaced with a complying septic tank as approved by the Board of Health.

* A metal septic tank will pass inspection if it is structurally sound, not leaking and if a Certificate of Compliance indicating that the tank is less than 20 years old is available.

☐ Y ☐ N ☐ ND (Explain below):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

C. Inspection Summary (cont.)

2) System Conditionally Passes (cont.):

☐ Pump Chamber pumps/alarms not operational. System will pass with Board of Health approval if pumps/alarms are repaired.

☐ Observation of sewage backup or break out or high static water level in the distribution box due to broken or obstructed pipe(s) or due to a broken, settled or uneven distribution box. System will pass inspection if (with approval of Board of Health):

☐ broken pipe(s) are replaced ☐ Y ☐ N ☐ ND (Explain below):

☐ obstruction is removed ☐ Y ☐ N ☐ ND (Explain below):

☐ distribution box is leveled or replaced ☐ Y ☐ N ☐ ND (Explain below):

☐ The system required pumping more than 4 times a year due to broken or obstructed pipe(s). The system will pass inspection if (with approval of the Board of Health):

☐ broken pipe(s) are replaced ☐ Y ☐ N ☐ ND (Explain below):

☐ obstruction is removed ☐ Y ☐ N ☐ ND (Explain below):

3) Further Evaluation is Required by the Board of Health:

☒ Conditions exist which require further evaluation by the Board of Health in order to determine if the system is failing to protect public health, safety or the environment.

a. System will pass unless Board of Health determines in accordance with 310 CMR 15.303(1)(b) that the system is not functioning in a manner which will protect public health, safety and the environment:



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

C. Inspection Summary (cont.)

- ☐ Cesspool or privy is within 50 feet of a surface water
- ☐ Cesspool or privy is within 50 feet of a bordering vegetated wetland or a salt marsh

b. System will fail unless the Board of Health (and Public Water Supplier, if any) determines that the system is functioning in a manner that protects the public health, safety and environment:

- ☐ The system has a septic tank and soil absorption system (SAS) and the SAS is within 100 feet of a surface water supply or tributary to a surface water supply.
- ☐ The system has a septic tank and SAS and the SAS is within a Zone 1 of a public water supply.
- ☐ The system has a septic tank and SAS and the SAS is within 50 feet of a private water supply well.
- ☐ The system has a septic tank and SAS and the SAS is less than 100 feet but 50 feet or more from a private water supply well**.

Method used to determine distance: _____

** This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis must be attached to this form.

c. Other:

4) System Failure Criteria Applicable to All Systems:

You must indicate "Yes" or "No" to each of the following for all inspections:

Yes No

☐

☒

Backup of sewage into facility or system component due to overloaded or clogged SAS or cesspool

☐

☒

Discharge or ponding of effluent to the surface of the ground or surface waters due to an overloaded or clogged SAS or cesspool



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

Owner
information is
required for every
page.

C. Inspection Summary (cont.)

4) System Failure Criteria Applicable to All Systems: (cont.)

Yes No

☐☒

Static liquid level in the distribution box above outlet invert due to an overloaded or clogged SAS or cesspool

☐☒

Liquid depth in cesspool is less than 6" below invert or available volume is less than ½ day flow

☐☒

Required pumping more than 4 times in the last year **NOT** due to clogged or obstructed pipe(s). Number of times pumped: _____

☐☒

Any portion of the SAS, cesspool or privy is below high ground water elevation.

☐☒

Any portion of cesspool or privy is within 100 feet of a surface water supply or tributary to a surface water supply.

☐☒

Any portion of a cesspool or privy is within a Zone 1 of a public water supply well.

☐☒

Any portion of a cesspool or privy is within 50 feet of a private water supply well.

☐☒

Any portion of a cesspool or privy is less than 100 feet but greater than 50 feet from a private water supply well with no acceptable water quality analysis. **[This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis and chain of custody must be attached to this form.]**

☐☒

The system is a cesspool serving a facility with a design flow of 2000 gpd-10,000 gpd.

☐☒

The system fails. I have determined that one or more of the above failure criteria exist as described in 310 CMR 15.303, therefore the system fails. The system owner should contact the Board of Health to determine what will be necessary to correct the failure.

5) Large Systems: To be considered a large system the system must serve a facility with a design flow of 10,000 gpd to 15,000 gpd.

For large systems, you must indicate either "yes" or "no" to each of the following, in addition to the questions in Section C.4.

Yes No

☐☐

the system is within 400 feet of a surface drinking water supply

☐☐

the system is within 200 feet of a tributary to a surface drinking water supply

☐☐

the system is located in a nitrogen sensitive area (Interim Wellhead Protection Area – IWPA) or a mapped Zone II of a public water supply well



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA
State

01944
Zip Code

July 19, 2023
Date of Inspection

C. Inspection Summary (cont.)

If you have answered "yes" to any question in Section C.5 the system is considered a significant threat, or answered "yes" to any question in Section C.4 above the large system has failed. The owner or operator of any large system considered a significant threat under Section C.5 or failed under Section C.4 shall upgrade the system in accordance with 310 CMR 15.304. The system owner should contact the appropriate regional office of the Department.

6. You must indicate "yes" or "no" for each of the following for *all* inspections:

Yes No

- | | | |
|-------------------------------------|-------------------------------------|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Pumping information was provided by the owner, occupant, or Board of Health |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Were any of the system components pumped out in the previous two weeks? |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Has the system received normal flows in the previous two week period? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Have large volumes of water been introduced to the system recently or as part of this inspection? |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Were as built plans of the system obtained and examined? (If they were not available note as N/A) |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Was the facility or dwelling inspected for signs of sewage back up? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Was the site inspected for signs of break out? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Were all system components, excluding the SAS, located on site? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Were the septic tank manholes uncovered, opened, and the interior of the tank inspected for the condition of the baffles or tees, material of construction, dimensions, depth of liquid, depth of sludge and depth of scum? |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Was the facility owner (and occupants if different from owner) provided with information on the proper maintenance of subsurface sewage disposal systems? The size and location of the Soil Absorption System (SAS) on the site has been determined based on: |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Existing information. For example, a plan at the Board of Health. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Determined in the field (if any of the failure criteria related to Part C is at issue approximation of distance is unacceptable) [310 CMR 15.302(5)] |



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information

1. Residential Flow Conditions:

Number of bedrooms (design): 3 Number of bedrooms (actual): 3

DESIGN flow based on 310 CMR 15.203 (for example: 110 gpd x # of bedrooms): 330

Description:

This is a 3-bedroom apartment over the carriage house. The unit is occupied sporadically. The two weeks prior to the inspection it was occupied by two people who left on July 17. When not occupied by people in residence, the bathrooms and laundry are used by people who work in and around the property.

Number of current residents: 0

Does residence have a garbage grinder? ☐ Yes ☒ No

Does residence have a water treatment unit? ☐ Yes ☒ No

If yes, discharges to:

Is laundry on a separate sewage system? (Include laundry system inspection information in this report.) ☐ Yes ☒ No

Laundry system inspected? ☒ Yes ☐ No

Seasonal use? ☐ Yes ☒ No

Water meter readings, if available (last 2 years usage (gpd)): 38

Detail:

Water consumption for the last 280 days were analyzed. Total usage was 31,416 gallons. The average daily flow was 38 GPD, the maximum 99 GPD, the minimum 8 GPD.

Sump pump? ☒ Yes ☐ No

Last date of occupancy: 7/17/2023

Date



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

2. Commercial/Industrial Flow Conditions:

Type of Establishment:

Design flow (based on 310 CMR 15.203):

Gallons per day (gpd)

Basis of design flow (seats/persons/sq.ft., etc.):

Grease trap present?

☐ Yes ☐ No

Water treatment unit present?

☐ Yes ☐ No

If yes, discharges to:

Industrial waste holding tank present?

☐ Yes ☐ No

Non-sanitary waste discharged to the Title 5 system?

☐ Yes ☐ No

Water meter readings, if available:

Last date of occupancy/use:

Date

Other (describe below):

3. Pumping Records:

Source of information:

Property Manager

Was system pumped as part of the inspection?

☒ Yes ☐ No

If yes, volume pumped:

350
gallons

How was quantity pumped determined?

Pump Truck gauge

Reason for pumping:

It is a cesspool



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

4. Type of System:

- ☐ Septic tank, distribution box, soil absorption system
- ☐ Single cesspool
- ☒ Overflow cesspool
- ☐ Privy
- ☐ Shared system (yes or no) (if yes, attach previous inspection records, if any)
- ☐ Innovative/Alternative technology. Attach a copy of the current operation and maintenance contract (to be obtained from system owner) and a copy of latest inspection of the I/A system by system operator under contract
- ☐ Tight tank. Attach a copy of the DEP approval.
- ☐ Other (describe):

Approximate age of all components, date installed (if known) and source of information:

50 plus years

Were sewage odors detected when arriving at the site?

☐ Yes ☒ No

5. Building Sewer (locate on site plan):

Depth below grade:

2.5
feet

Material of construction:

☐ cast iron

☐ 40 PVC

☒ other (explain):

Clay

Distance from private water supply well or suction line:

N/A
feet

Comments (on condition of joints, venting, evidence of leakage, etc.):

no evidence of leakage



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

6. Septic Tank (locate on site plan):

Depth below grade:

Cast iron cover at grade
feet

Material of construction:

☐ concrete

☐ metal

☐ fiberglass

☐ polyethylene

☒ other (explain)

The unit is Field Stone cesspool; there is no evidence that it overflows to the second concrete block cesspool; currently there are no baffles or tees. In the inspectors opinion the unit functions as a cesspool.

If tank is metal, list age:

years

Is age confirmed by a Certificate of Compliance? (attach a copy of certificate)

☐ Yes

☐ No

Dimensions:

Approximately 80-inches dia.

Sludge depth:

6-inches

Distance from top of sludge to bottom of outlet tee or baffle

N/A - No tees present

Scum thickness

nil

Distance from top of scum to top of outlet tee or baffle

N/A

Distance from bottom of scum to bottom of outlet tee or baffle

N/A

How were dimensions determined?

Probe and tape measure

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

As a septic tank it is a complete failure. As a cesspool it functions well. The unit was pumped for the inspection. There are no tees or baffles, the field stone structure appears to be structurally sound. The bottom of the pit is 8 feet 4 inches (100-inches) below finished grade. The liquid level was 17-inches and the sludge 6-inches. See additional details as a cesspool in Section D 12 (page 14).



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

7. Grease Trap (locate on site plan):

Depth below grade:

feet

Material of construction:

☐ concrete

☐ metal

☐ fiberglass

☐ polyethylene

☐ other (explain):

Dimensions:

Scum thickness

Distance from top of scum to top of outlet tee or baffle

Distance from bottom of scum to bottom of outlet tee or baffle

Date of last pumping:

Date

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

8. Tight or Holding Tank (tank must be pumped at time of inspection) (locate on site plan):

Depth below grade:

Material of construction:

☐ concrete

☐ metal

☐ fiberglass

☐ polyethylene

☐ other (explain):

Dimensions:

Capacity:

gallons

Design Flow:

gallons per day



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

8. Tight or Holding Tank (cont.)

Alarm present:

☐ Yes ☐ No

Alarm level: _____

Alarm in working order: ☐ Yes ☐ No

Date of last pumping: _____

Date

Comments (condition of alarm and float switches, etc.):

* Attach copy of current pumping contract (required). Is copy attached?

☐ Yes ☐ No

9. Distribution Box (if present must be opened) (locate on site plan):

Depth of liquid level above outlet invert _____

Comments (note if box is level and distribution to outlets equal, any evidence of solids carryover, any evidence of leakage into or out of box, etc.):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

10. Pump Chamber (locate on site plan):

Pumps in working order:

☐ Yes ☐ No*

Alarms in working order:

☐ Yes ☐ No*

Comments (note condition of pump chamber, condition of pumps and appurtenances, etc.):

* If pumps or alarms are not in working order, system is a conditional pass.

11. Soil Absorption System (SAS) (locate on site plan, excavation not required):

If SAS not located, explain why:

Type:

- | | | | |
|-------------------------------------|-------------------------------|---------------------|---------|
| <input type="checkbox"/> | leaching pits | number: | _____ |
| <input type="checkbox"/> | leaching chambers | number: | _____ |
| <input type="checkbox"/> | leaching galleries | number: | _____ |
| <input type="checkbox"/> | leaching trenches | number, length: | _____ |
| <input type="checkbox"/> | leaching fields | number, dimensions: | _____ |
| <input checked="" type="checkbox"/> | overflow cesspool | number: | 1 _____ |
| <input type="checkbox"/> | innovative/alternative system | | |

Type/name of technology: _____



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

11. Soil Absorption System (SAS) (cont.)

Comments (note condition of soil, signs of hydraulic failure, level of ponding, damp soil, condition of vegetation, etc.):

No liquid in the unit. No indication of malfunction.

12. Cesspools (cesspool must be pumped as part of inspection) (locate on site plan):

Number and configuration

2 including the overflow

Depth – top of liquid to inlet invert

43-inches

Depth of solids layer

6-inches

Depth of scum layer

nil

Dimensions of cesspool

80-inches diameter

Materials of construction

fieldstone

Indication of groundwater inflow

☐ Yes ☒ No

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):

The 1st cesspool appears to function well. There are no sign of failure, ponding or vegetaion issues. The 2nd cesspool has no evidence that it receives any flow. It is a built with concrete blocks, the bottom is no sludge, no scum and no liquid. The bottom is 6.5 feet (78-inches) below grade. The unit appears to be structually sound.



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

13. Privy (locate on site plan):

Materials of construction:

Dimensions

Depth of solids

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

14. Sketch Of Sewage Disposal System:

Provide a view of the sewage disposal system, including ties to at least two permanent reference landmarks or benchmarks. Locate all wells within 100 feet. Locate where public water supply enters the building. Check one of the boxes below:

- ☐ hand-sketch in the area below
☒ drawing attached separately



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner
information is
required for every
page.

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

City/Town

MA

State

01944

Zip Code

July 19, 2023

Date of Inspection

D. System Information (cont.)

15. Site Exam:

☒ Check Slope

☒ Surface water

☒ Check cellar

☐ Shallow wells

Estimated depth to high ground water:

Greater than 100 inches
feet

Please indicate all methods used to determine the high ground water elevation:

☐ Obtained from system design plans on record

If checked, date of design plan reviewed:

Date

☐ Observed site (abutting property/observation hole within 150 feet of SAS)

☐ Checked with local Board of Health - explain:

☐ Checked with local excavators, installers - (attach documentation)

☒ Accessed USGS database - explain:

Checked current condition for the Wenham well.

You **must** describe how you established the high ground water elevation:

1) checked the cesspool after it was pumped; 2) Review the soil evaluation data for the Min House at 29 Old Neck Road, 1 Eagle Head Road and 3 Eagle Head Road; 3) Check the current condition of the USGS Wenham well; 4) Used the USDA Soil Survey for ground water depth 242B Hinckley soil. 5) Relied on my own knowledge based on previous work in the area.

Before filing this Inspection Report, please see Report Completeness Checklist on next page.



Owner
information is
required for every
page.

Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

29 Old Neck Road - Carriage House

Property Address

29 Old Neck Road Trust

Owner's Name

Manchester

MA

01944

July 19, 2023

City/Town

State

Zip Code

Date of Inspection

E. Report Completeness Checklist

Complete all applicable sections of this form inclusive of:

☒ A. Inspector Information: Complete all fields in this section.

☒ B. Certification: Signed & Dated and 1, 2, 3, or 4 checked

☒ C. Inspection Summary:

1, 2, 3, or 5 completed as appropriate

4 (Failure Criteria) and 6 (Checklist) completed

☒ D. System Information:

For 8: Tight/Holding Tank – Pumping contract attached

For 14: Sketch of Sewage Disposal System drawn on pg. 16 or attached

For 15: Explanation of estimated depth to high groundwater included



