



MANCHESTER-BY-THE-SEA

BOARD OF HEALTH

TOWN HALL - 10 CENTRAL STREET

Manchester-by-the-Sea, Massachusetts 01944-1399

Telephone (978) 526-7385

FAX (978) 526-2009

October 12, 2023

Jean Woodberry
142 Bridge Street
Manchester-by-the-Sea, MA 01944

NOTIFICATION TO OWNER

Upon receipt of the Title 5 Inspection Report for the onsite sewage disposal system at:

Property Address: **142 BRIDGE STREET, MANCHESTER-BY-THE-SEA**

Property Owner: WOODBERRY TE JEAN V and 142 BRIDGE ST RLTY TR


Licensed Title 5 Inspector: Jonathan Granz, Preventative Septic Services SI# 13405

The Title 5 Inspection Report dated 9/19/2023, states the system **PASSES**.

NOTE: The septic tank was not pumped as part of the inspection.

The Board of Health DID NOT find the septic system, as it is now used, to constitute a danger to the public health and subsequently did not order its repair/replacement at this time.

Reviewing Board of Health Agent:



Wendy Hansbury RS, Public Health Director

THIS INSPECTION reflects the **present** condition of the sanitary disposal system and is not any guarantee as to the life or future condition of said system. A passing Title 5 Inspection Report with pump receipts for three years within each calendar year may be used for sale of property. (Explanation: If there is a potential that your home will be sold within three years, you **MUST** have the septic tank pumped once a year, within a year of the date of the approved Title 5 Inspection Report for each of the three years. This allows the sale to occur with the use of the pumping reports and annual receipts abates the need for a "Title 5 System Inspection" for a property transfer within three years of the passing inspection, otherwise a passing Title 5 Inspection Report is only good for two years.)



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments



142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

MA

01944

9/19/23

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

Inspection results must be submitted on this form. Inspection forms may not be altered in any way. Please see completeness checklist at the end of the form.

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



A. Inspector Information

Jonathan J. Granz

Name of Inspector

Preventative Septic Services

Company Name

46 Beech Street

Company Address

South Hamilton

MA

01982

City/Town

State

Zip Code

978-468-9001

SI13405

Telephone Number

License Number

B. Certification

I certify that: **I am a DEP approved system inspector in full compliance with Section 15.340 of Title 5 (310 CMR 15.000)**; I have personally inspected the sewage disposal system at the property address listed above; the information reported below is true, accurate and complete as of the time of my inspection; and the inspection was performed based on my training and experience in the proper function and maintenance of on-site sewage disposal systems. After conducting this inspection I have determined that the system:

- 1. Passes
- 2. Conditionally Passes
- 3. Needs Further Evaluation by the Local Approving Authority
- 4. Fails

Inspector's Signature

10/6/23

Date

The system inspector shall submit a copy of this inspection report to the Approving Authority (Board of Health or DEP) within 30 days of completing this inspection. If the system has a design flow of 10,000 gpd or greater, the inspector and the system owner shall submit the report to the appropriate regional office of the DEP. The original form should be sent to the system owner and copies sent to the buyer, if applicable, and the approving authority.

Please note: This report only describes conditions at the time of inspection and under the conditions of use at that time. This inspection does not address how the system will perform in the future under the same or different conditions of use.



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

C. Inspection Summary

Inspection Summary: Complete 1, 2, 3, or 5 and all of 4 and 6.

1) System Passes:

I have not found any information which indicates that any of the failure criteria described in 310 CMR 15.303 or in 310 CMR 15.304 exist. Any failure criteria not evaluated are indicated below.

Comments:

System is working properly.

The septic tank has a Orenco effluent filter in the outlet tee, it should be cleaned atleast once a year

2) System Conditionally Passes:

One or more system components as described in the "Conditional Pass" section need to be replaced or repaired. The system, upon completion of the replacement or repair, as approved by the Board of Health, will pass.

Check the box for "yes", "no" or "not determined" (Y, N, ND) for the following statements. If "not determined," please explain.

The septic tank is metal and over 20 years old* or the septic tank (whether metal or not) is structurally unsound, exhibits substantial infiltration or exfiltration or tank failure is imminent. System will pass inspection if the existing tank is replaced with a complying septic tank as approved by the Board of Health.

* A metal septic tank will pass inspection if it is structurally sound, not leaking and if a Certificate of Compliance indicating that the tank is less than 20 years old is available.

Y N ND (Explain below):



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

MA

01944

9/19/23

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

C. Inspection Summary (cont.)

2) System Conditionally Passes (cont.):

Pump Chamber pumps/alarms not operational. System will pass with Board of Health approval if pumps/alarms are repaired.

Observation of sewage backup or break out or high static water level in the distribution box due to broken or obstructed pipe(s) or due to a broken, settled or uneven distribution box. System will pass inspection if (with approval of Board of Health):

broken pipe(s) are replaced Y N ND (Explain below):

obstruction is removed Y N ND (Explain below):

distribution box is leveled or replaced Y N ND (Explain below):

The system required pumping more than 4 times a year due to broken or obstructed pipe(s). The system will pass inspection if (with approval of the Board of Health):

broken pipe(s) are replaced Y N ND (Explain below):

obstruction is removed Y N ND (Explain below):

3) Further Evaluation is Required by the Board of Health:

Conditions exist which require further evaluation by the Board of Health in order to determine if the system is failing to protect public health, safety or the environment.

a. System will pass unless Board of Health determines in accordance with 310 CMR 15.303(1)(b) that the system is not functioning in a manner which will protect public health, safety and the environment:



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

MA

01944

9/19/23

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

C. Inspection Summary (cont.)

- Cesspool or privy is within 50 feet of a surface water
- Cesspool or privy is within 50 feet of a bordering vegetated wetland or a salt marsh

b. System will fail unless the Board of Health (and Public Water Supplier, if any) determines that the system is functioning in a manner that protects the public health, safety and environment:

- The system has a septic tank and soil absorption system (SAS) and the SAS is within 100 feet of a surface water supply or tributary to a surface water supply.
- The system has a septic tank and SAS and the SAS is within a Zone 1 of a public water supply.
- The system has a septic tank and SAS and the SAS is within 50 feet of a private water supply well.
- The system has a septic tank and SAS and the SAS is less than 100 feet but 50 feet or more from a private water supply well**.

Method used to determine distance: _____

** This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis must be attached to this form.

c. Other:

4) System Failure Criteria Applicable to All Systems:

You must indicate "Yes" or "No" to each of the following for all inspections:

- | | | |
|--------------------------|-------------------------------------|---|
| Yes | No | |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Backup of sewage into facility or system component due to overloaded or clogged SAS or cesspool |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Discharge or ponding of effluent to the surface of the ground or surface waters due to an overloaded or clogged SAS or cesspool |



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

MA

01944

9/19/23

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

C. Inspection Summary (cont.)

4) System Failure Criteria Applicable to All Systems: (cont.)

Yes No

Static liquid level in the distribution box above outlet invert due to an overloaded or clogged SAS or cesspool

Liquid depth in cesspool is less than 6" below invert or available volume is less than 1/2 day flow

Required pumping more than 4 times in the last year **NOT** due to clogged or obstructed pipe(s). Number of times pumped: _____.

Any portion of the SAS, cesspool or privy is below high ground water elevation.

Any portion of cesspool or privy is within 100 feet of a surface water supply or tributary to a surface water supply.

Any portion of a cesspool or privy is within a Zone 1 of a public water supply well.

Any portion of a cesspool or privy is within 50 feet of a private water supply well.

Any portion of a cesspool or privy is less than 100 feet but greater than 50 feet from a private water supply well with no acceptable water quality analysis. **[This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis and chain of custody must be attached to this form.]**

The system is a cesspool serving a facility with a design flow of 2000 gpd-10,000 gpd.

The system fails. I have determined that one or more of the above failure criteria exist as described in 310 CMR 15.303, therefore the system fails. The system owner should contact the Board of Health to determine what will be necessary to correct the failure.

5) Large Systems: To be considered a large system the system must serve a facility with a design flow of 10,000 gpd to 15,000 gpd.

For large systems, you must indicate either "yes" or "no" to each of the following, in addition to the questions in Section C.4.

Yes No

the system is within 400 feet of a surface drinking water supply

the system is within 200 feet of a tributary to a surface drinking water supply

the system is located in a nitrogen sensitive area (Interim Wellhead Protection Area – IWPA) or a mapped Zone II of a public water supply well



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

City/Town

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

C. Inspection Summary (cont.)

If you have answered "yes" to any question in Section C.5 the system is considered a significant threat, or answered "yes" to any question in Section C.4 above the large system has failed. The owner or operator of any large system considered a significant threat under Section C.5 or failed under Section C.4 shall upgrade the system in accordance with 310 CMR 15.304. The system owner should contact the appropriate regional office of the Department.

6. You must indicate "yes" or "no" for each of the following for *all* inspections:

Yes No

- Pumping information was provided by the owner, occupant, or Board of Health
- Were any of the system components pumped out in the previous two weeks?
- Has the system received normal flows in the previous two week period?
- Have large volumes of water been introduced to the system recently or as part of this inspection?
- N/A* Were as built plans of the system obtained and examined? (If they were not available note as N/A)
- Was the facility or dwelling inspected for signs of sewage back up?
- Was the site inspected for signs of break out?
- Were all system components, excluding the SAS, located on site?
- Were the septic tank manholes uncovered, opened, and the interior of the tank inspected for the condition of the baffles or tees, material of construction, dimensions, depth of liquid, depth of sludge and depth of scum?
- Was the facility owner (and occupants if different from owner) provided with information on the proper maintenance of subsurface sewage disposal systems? **The size and location of the Soil Absorption System (SAS) on the site has been determined based on:**
- Existing information. For example, a plan at the Board of Health.
- Determined in the field (if any of the failure criteria related to Part C is at issue approximation of distance is unacceptable) [310 CMR 15.302(5)]



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

City/Town

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information

1. Residential Flow Conditions:

Number of bedrooms (design): 3 Number of bedrooms (actual): 3

DESIGN flow based on 310 CMR 15.203 (for example: 110 gpd x # of bedrooms): 330

Description:

System is composed of a 1500 gallon double compartment septic tank, pump chamber, distribution box and a 46'x10' leaching field.

Number of current residents: 1

Does residence have a garbage grinder? Yes No

Does residence have a water treatment unit? Yes No

If yes, discharges to: _____

Is laundry on a separate sewage system? (Include laundry system inspection information in this report.) Yes No

Laundry system inspected? N/A Yes No

Seasonal use? Yes No

Water meter readings, if available (last 2 years usage (gpd)): 25.65 GPD

Detail:

Water meter readings were provided by the Manchester water department, usage was averaged from 7/7/21-7/6/23, 729 days (see attached).

Sump pump? Yes No

Last date of occupancy: Current
Date



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

Owner information is required for every page.

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

City/Town

MA

State

01944

Zip Code

9/19/23

Date of Inspection

D. System Information (cont.)

2. Commercial/Industrial Flow Conditions:

Type of Establishment: _____

Design flow (based on 310 CMR 15.203): _____

Gallons per day (gpd)

Basis of design flow (seats/persons/sq.ft., etc.): _____

Grease trap present?

Yes No

Water treatment unit present?

Yes No

If yes, discharges to: _____

Industrial waste holding tank present?

Yes No

Non-sanitary waste discharged to the Title 5 system?

Yes No

Water meter readings, if available: _____

Last date of occupancy/use: _____

Date

Other (describe below):

3. Pumping Records:

Source of information: _____

Not pumped since installation in 2006, per Homeowner

Was system pumped as part of the inspection?

Yes No

If yes, volume pumped: _____

gallons

How was quantity pumped determined? _____

Reason for pumping: _____



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

City/Town

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

4. Type of System:

- Septic tank, distribution box, soil absorption system
- Single cesspool
- Overflow cesspool
- Privy
- Shared system (yes or no) (if yes, attach previous inspection records, if any)
- Innovative/Alternative technology. Attach a copy of the current operation and maintenance contract (to be obtained from system owner) and a copy of latest inspection of the I/A system by system operator under contract
- Tight tank. Attach a copy of the DEP approval.
- Other (describe):
Septic tank, pump chamber, distribution box, soil absorption system.

Approximate age of all components, date installed (if known) and source of information:

The system was installed in 2006, exact date is not clear (BOH records).

Were sewage odors detected when arriving at the site?

Yes No

5. Building Sewer (locate on site plan):

Depth below grade:

25"
feet

Material of construction:

cast iron 40 PVC other (explain):

Distance from private water supply well or suction line:

n/a
feet

Comments (on condition of joints, venting, evidence of leakage, etc.):

Building sewer appear to be in good condition, there is no evidence of any backup or problems. Constructed of cast iron at foundation, PVC at tank.



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

City/Town

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

6. Septic Tank (locate on site plan):

Depth below grade:

18"

feet

Material of construction:

concrete

metal

fiberglass

polyethylene

other (explain)

If tank is metal, list age:

years

Is age confirmed by a Certificate of Compliance? (attach a copy of certificate)

Yes

No

Dimensions:

4'D x 10'L x 5'W

Sludge depth:

6" 1st, <2" 2nd

Distance from top of sludge to bottom of outlet tee or baffle

32"

Scum thickness

0" 1st, 0" 2nd

Distance from top of scum to top of outlet tee or baffle

6"

Distance from bottom of scum to bottom of outlet tee or baffle

14"

How were dimensions determined?

Sludge Judge/tape measure

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

The 1500 gallon double compartment tank is in good condition, structurally sound, no leakage in or out, liquid level at outlet invert, inlet, center and outlet have PVC tees, all in good condition. The inlet and outlet covers are at grade. There is a Orenco filter in the outlet tee (cleaned at time of inspection). Tank does not need to be pumped at this time.



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

City/Town

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

7. Grease Trap (locate on site plan):

Depth below grade:

_____ feet

Material of construction:

concrete

metal

fiberglass

polyethylene

other (explain):

Dimensions: _____

Scum thickness _____

Distance from top of scum to top of outlet tee or baffle _____

Distance from bottom of scum to bottom of outlet tee or baffle _____

Date of last pumping: _____

Date

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

8. Tight or Holding Tank (tank must be pumped at time of inspection) (locate on site plan):

Depth below grade: _____

Material of construction:

concrete

metal

fiberglass

polyethylene

other (explain):

Dimensions: _____

Capacity: _____

gallons

Design Flow: _____

gallons per day



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

City/Town

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

8. Tight or Holding Tank (cont.)

Alarm present:

Yes No

Alarm level: _____

Alarm in working order: Yes No

Date of last pumping:

_____ Date

Comments (condition of alarm and float switches, etc.):

* Attach copy of current pumping contract (required). Is copy attached?

Yes No

9. Distribution Box (if present must be opened) (locate on site plan):

Depth of liquid level above outlet invert

0" _____

Comments (note if box is level and distribution to outlets equal, any evidence of solids carryover, any evidence of leakage into or out of box, etc.):

The distribution box is in good condition, structually sound, no signs of leakage, speed levels are present and adjusted properly. There is a riser bringing the cover to grade. Outlet inverts are 24" below grade.



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

10. Pump Chamber (locate on site plan):

Pumps in working order:

Yes No*

Alarms in working order:

Yes No*

Comments (note condition of pump chamber, condition of pumps and appurtenances, etc.):

The pump chamber was found to be in good condition, the floats, pump and alarm were tested and all function properly. The cover is at grade.

* If pumps or alarms are not in working order, system is a conditional pass.

11. Soil Absorption System (SAS) (locate on site plan, excavation not required):

If SAS not located, explain why:

Type:

leaching pits number: _____

leaching chambers number: _____

leaching galleries number: _____

leaching trenches number, length: _____

leaching fields number, dimensions: 1@ 46'x10'

overflow cesspool number: _____

innovative/alternative system

Type/name of technology: _____



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

11. Soil Absorption System (SAS) (cont.)

Comments (note condition of soil, signs of hydraulic failure, level of ponding, damp soil, condition of vegetation, etc.):

Soil over system is dry and consistant with surrounding yard with no signs of ponding, breakout or abnormal vegetation. The field was "dosed" at time of inspection, it was found to drain properly.

12. Cesspools (cesspool must be pumped as part of inspection) (locate on site plan):

Number and configuration

Depth – top of liquid to inlet invert

Depth of solids layer

Depth of scum layer

Dimensions of cesspool

Materials of construction

Indication of groundwater inflow

Yes No

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

City/Town

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

13. Privy (locate on site plan):

Materials of construction:

Dimensions

Depth of solids

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):

Four horizontal lines for handwritten comments.



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

14. Sketch Of Sewage Disposal System:

Provide a view of the sewage disposal system, including ties to at least two permanent reference landmarks or benchmarks. Locate all wells within 100 feet. Locate where public water supply enters the building. Check one of the boxes below:

- hand-sketch in the area below
- drawing attached separately



Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

City/Town

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

15. Site Exam:

Check Slope

Surface water

Check cellar

Shallow wells

Estimated depth to high ground water:

2'-4' below original grade
feet

Please indicate all methods used to determine the high ground water elevation:

Obtained from system design plans on record

If checked, date of design plan reviewed: 11/8/05
Date

Observed site (abutting property/observation hole within 150 feet of SAS)

Checked with local Board of Health - explain:

Soil data from design of system.

Checked with local excavators, installers - (attach documentation)

Accessed USGS database - explain:

You **must** describe how you established the high ground water elevation:

Soil tests were performed at this property for the design of this system on 7/7/05 by John Bennett, witnessed by Gerald McDonald, ESHWT was found at 48" in TP-1, ESHWT found at 24" below grade in TP-2 (see BOH records). This system was designed/installed with a 4' separation from ESHWT, it is not interfacing with ground water/ESHWT.

Before filing this Inspection Report, please see Report Completeness Checklist on next page.



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

142 Bridge Street

Property Address

Jean Woodberry

Owner's Name

Manchester by the Sea

MA

State

01944

Zip Code

9/19/23

Date of Inspection

Owner information is required for every page.

E. Report Completeness Checklist

Complete all applicable sections of this form inclusive of:

A. Inspector Information: Complete all fields in this section.

B. Certification: Signed & Dated and 1, 2, 3, or 4 checked

C. Inspection Summary:

1, 2, 3, or 5 completed as appropriate

4 (Failure Criteria) and 6 (Checklist) completed


D. System Information:

For 8: Tight/Holding Tank – Pumping contract attached

For 14: Sketch of Sewage Disposal System drawn on pg. 16 or attached

For 15: Explanation of estimated depth to high groundwater included

Label Detail
10 Scale



TIES

- A-1-16'
- A-2-30'2"
- A-3-32'9"
- A-4-47'7"
- B-1-22'8"
- B-2-16'7"
- B-3-28'1"
- B-4-47'8"

MAG 14

14
29.56
MAG 14


11
30.53
MAG 11

Proposed
4" SCH 40
Vent Header
(2 required)

Vent Riser** with
Charcoal Filter
(2 Required)

2" SCH 40 PVC
Force Main
(See Profile)

Proposed
4" SCH 40 PVC
(See Profile)



rv. (Out) = 28.0±


Proposed
Building Sewer
4" SCH 40 PVC
Connect to Existing
(See Profile)

Proposed
1500 Gallon H-20
2 Compartment
Septic Tank with
Effluent Filter
2 CI Manholes to Grade
Confirm Building Sewer
before setting any units.

Proposed
6 foot I.D.
Pumping Station
See Details

SAS
10'
Remove & Replace
20'

Elastic Barrier Vent Header





Customer Transaction Summary

Customer Information
 Account No: 802270
 LARRY WOODBERRY
 142 BRIDGE STREET
 MANCHESTER, MA 01944

Location Information
 Location No: 1209700
 142 BRIDGE STREET
 MANCHESTER, MA 01944

Date	Type	More Info	Reading	Usage	Prior Balance	Transaction Amount	Balance
05/16/2018	Charge	04/13/2018	1132 1	300	0.00	17.04	17.04
06/06/2018	Payment	CHECK			17.04	-17.04	0.00
08/15/2018	Charge	07/11/2018	1137 1	500	0.00	28.40	28.40
09/04/2018	Payment	CHECK			28.40	-28.40	0.00
11/15/2018	Charge	10/04/2018	1140 1	300	0.00	17.67	17.67
12/03/2018	Payment				17.67	-17.67	0.00
02/15/2019	Charge	01/08/2019	1144 1	400	0.00	23.56	23.56
03/05/2019	Payment	CHECK			23.56	-23.56	0.00
05/15/2019	Charge	04/09/2019	1147 1	300	0.00	17.67	17.67
05/30/2019	Payment	CHECK			17.67	-17.67	0.00
08/15/2019	Charge	07/12/2019	1151 1	400	0.00	24.44	24.44
09/03/2019	Payment	CHECK			24.44	-24.44	0.00
11/15/2019	Charge	10/08/2019	1154 1	300	0.00	18.33	18.33
12/04/2019	Payment	CHECK			18.33	-18.33	0.00
02/15/2020	Charge	01/08/2020	1157 1	300	0.00	18.33	18.33
03/02/2020	Payment	CHECK			18.33	-18.33	0.00
05/15/2020	Charge	04/06/2020	1160 1	300	0.00	18.33	18.33
06/03/2020	Payment	CCC			18.33	-18.33	0.00
08/17/2020	Charge	07/14/2020	1169 1	900	0.00	54.99	54.99
09/03/2020	Payment	CCC			54.99	-54.99	0.00
11/16/2020	Charge	10/06/2020	1173 1	400	0.00	24.88	24.88
12/02/2020	Payment	CHECK			24.88	-24.88	0.00
02/16/2021	Charge	01/06/2021	1176 1	300	0.00	18.66	18.66
03/04/2021	Payment	CCC			18.66	-18.66	0.00
05/17/2021	Charge	04/07/2021	1179 1	300	0.00	18.66	18.66
06/03/2021	Payment	CCC			18.66	-18.66	0.00
08/16/2021	Charge	07/07/2021	1182 1	300	0.00	18.66	18.66
09/02/2021	Payment	CCC			18.66	-18.66	0.00
11/15/2021	Charge	10/05/2021	1185 1	300	0.00	19.08	19.08
12/06/2021	Payment	CCC			19.08	-19.08	0.00
02/15/2022	Charge	01/04/2022	1188 1	300	0.00	19.08	19.08
03/07/2022	Payment	CCC			19.08	-19.08	0.00
05/16/2022	Charge	04/05/2022	1191 1	300	0.00	19.08	19.08
06/03/2022	Payment	CCC			19.08	-19.08	0.00
08/15/2022	Charge	07/13/2022	1194 1	300	0.00	19.08	19.08
09/07/2022	Payment	CCC			19.08	-19.08	0.00
11/15/2022	Charge	10/06/2022	1197 1	300	0.00	19.65	19.65
11/29/2022	Payment	CCC			19.65	-19.65	0.00
02/15/2023	Charge	01/05/2023	1200 1	300	0.00	19.65	19.65
03/10/2023	Payment	CCC			19.65	-19.65	0.00
05/15/2023	Charge	04/06/2023	1204 1	400	0.00	26.20	26.20
05/26/2023	Payment	CCC			26.20	-26.20	0.00
08/15/2023	Charge	07/06/2023	1207 1	300	0.00	19.65	19.65
09/01/2023	Payment	CCC			19.65	-19.65	0.00

X100 C.F.

7/7/21 - 7/6/23
18,700 GAL, 729 DAYS, 25.65 GPD