

November 6, 2023


TOWN OF MANCHESTER BY THE SEA, MASSACHUSETTS

DOCUMENTS AND SPECIFICATIONS

ON-CALL SEWER SERVICE LATERAL LINING

CONTRACT NO. 2023-1

ADDENDUM NO. 1



The following additions and/or alterations to the plans and specifications for the above-referenced contract are to be incorporated into all general bids for the proposed work.

Inclusion of this Addendum must be acknowledged by inserting the addendum number and date on Page 00300-1 of the specification section entitled "BID FORM." Failure to acknowledge any and all addenda in the above specified specification section may be cause for rejection of the bid by the OWNER on the grounds that it is not responsive to the "INSTRUCTIONS TO BIDDERS."

Bidder Questions

Q: What is the difference between bid item No. 1A and bid item No. 1D.

A. Bid item No. 1A includes Cured-in-Place Service Lateral Pipe Lining from Sewer Main up to 5-feet of Service Lateral Length with Full Wrap Top Hat that is in scope for Year 1 as shown in the Appendix. Bid item No. 1D includes 5-foot Full Wrap Top Hat for Sewer Service Lateral at the Direction of the Owner.

SPECIFICATIONS

1. Reference Specification Section 02765 SERVICE LATERAL CONNECTION LINER, Page02765-4. Delete Item No. 1.05.A.4 and replace with the following:
 - “4. ASTM F2561 – Standard Practice for Rehabilitation of a Sewer Service Lateral and Its Connection to the Main Using a One Piece Main and Lateral Cured-in-Place Liner. Excludes any requirement to meet patented processes in the standard.”

END OF ADDENDUM NO. 1